



Compress Test Report

AYRIKO Company


www.AYRIKO.ir
www.AYRIKO.com

The first manufacturer of digital pressure cylinder

Information engine


Code :	2	Unit Type :	perkins	Date Test :	98-3-19
Name :	cinaco	Unit Make :	trs2	Quantity Cylinder	16
Unit Particle :	a1-a10	Unit Model :	40000	RPM Engine :	1500
Location :	yazd	Capacity Engine	1000KW	RPM Start Engine	1500
Temp Environment	38	Temperature Oi	35	Density Ratio :	11

Address : yazde




Peak Table Pressure

12.97	14.34
13.56	14.41
13.76	14.14
13.82	14.03
13.92	14.18
14.05	14.24
14.25	14.22
14.43	13.97
14.51	13.97



Peak Table Pressure

14.72	16.12
15.25	15.99
15.49	15.82
15.68	15.81
15.61	15.91
15.77	15.86
16.03	15.78
15.88	15.59
16.15	15.73



Peak Table Pressure

15.13	15.50
15.29	15.12
15.54	15.21
15.55	15.19
15.32	15.29
15.35	15.23
15.50	15.04
15.52	15.07
15.42	15.17




Compress Test Report

AYRIKO Company


www.AYRIKO.ir
www.AYRIKO.com

The first manufacturer of digital pressure cylinder




Peak Table Pressure

12.84	14.13
13.72	13.97
14.13	13.92
14.22	13.86
14.23	13.82
13.93	13.69
14.14	13.87
14.25	13.90
14.11	13.77




Peak Table Pressure

15.16	15.86
15.77	15.43
15.91	15.50
15.99	15.55
15.78	15.69
15.73	15.72
15.90	15.62
15.96	15.44
15.82	15.60



Peak Table Pressure

13.87	15.29
15.16	15.39
15.44	15.02
15.45	14.94
15.56	15.00
15.36	15.20
15.22	15.27
15.44	15.10
15.46	14.94



Peak Table Pressure

14.93	15.39
15.48	15.41
15.50	15.24
15.40	15.17
15.51	15.11
15.55	15.22
15.39	15.32
15.64	15.20
15.69	15.00




Compress Test Report

AYRIKO Company

The first manufacturer of digital pressure cylinder

www.AYRIKO.ir
www.AYRIKO.com



Peak Table Pressure

2.94	15.85
15.35	15.55
15.60	15.59
15.73	15.52
15.61	15.44
15.67	15.45
15.74	15.31
15.54	15.45
15.82	15.37